

MINOR ELECTRICAL INSTALLATION MULTIPLE WORKS

Requirements For Electrical Installations - BS 7671



Certificate Reference:

1 DESCRIPTION OF THE MINOR WORKS

Client address: Brunel Management
Brunel Chambers, Devonshire Place, St Helier,
JE2 3RD

Installation address: 22 Belle Vue , La Route des Quennevais , St
Brelade, JE3 8NH

Description of the minor works:

1): New Kitchen. Cooker.

2): New Kitchen. Fridge.

3): New Kitchen. Washing Machine.

4): New Kitchen. Sockets.

5): N/A

Details of departures from BS 7671:2018 as amended to 2022 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5). Where applicable, a suitable risk assessment(s) must be attached to the Certificate:

None

Date minor works completed: Risk assessment attached:

Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):

Satisfactory.

2 PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS

System type and earthing arrangements: TN-C-S TN-S N/A TT N/A

Earth fault loop impedance at distribution board (Z_{db}) supplying the final circuit: Ω

Presence of adequate main protective conductors: Earthing Conductor

Main protective bonding conductor(s) to: Water Gas Oil N/A Structural Steel N/A Other:

3 DECLARATION

I/we certify that the work covered by this certificate does not impair the safety of the existing installation and the work have been designed, constructed, inspected and tested in accordance with BS 7671:2018 amended to 2022 and that to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title:

Address:



Postcode:

Registration Number (if applicable):

Telephone Number:

Name: Position: Signature: Date: