

# MINOR ELECTRICAL INSTALLATION MULTIPLE WORKS

Requirements For Electrical Installations - BS 7671 IET Wiring Regulations



Certificate Reference:

## 1 DESCRIPTION OF THE MINOR WORKS

Client address:	<input type="text" value="Brunel Management&lt;br/&gt;Brunel Management , Brunel Chambers,&lt;br/&gt;Devonshire place , St Helier , JE2 3RD"/>	Installation address:	<input type="text" value="23 Belle Vue , La Route Des Quennevais , St&lt;br/&gt;Brelade , JE3 8NH"/>
-----------------	--	-----------------------	--

Description of the minor works:

1):	<input type="text" value="Cooker"/>
2):	<input type="text" value="Ring main"/>
3):	<input type="text" value="Lights"/>
4):	<input type="text"/>
5):	<input type="text"/>

Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5):  
Where applicable, a suitable risk assessment(s) must be attached to the Certificate.

Date minor works completed:  Risk assessment attached:

Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):

## 2 PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS

System type and earthing arrangements:	TN-C-S <input checked="" type="checkbox"/>	TN-S <input type="checkbox"/>	TT <input type="checkbox"/>		
Earth fault loop impedance at distribution board (Zdb) supplying the final circuit:	<input type="text" value="0.25 Ω"/>				
Presence of adequate main protective conductors:	Earthing Conductor <input checked="" type="checkbox"/>				
Main protective bonding conductor(s) to:	Water <input checked="" type="checkbox"/>	Gas <input type="checkbox"/>	Oil <input type="checkbox"/>	Structural Steel <input type="checkbox"/>	Other: <input type="text" value="N/A"/>

## 3 TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED

See Page 2 for circuit details and test results.

Details of Test Instruments used (state serial and/or asset numbers):

Multi-functional:	<input type="text" value="1234567"/>	Earth electrode resistance:	<input type="text" value="N/A"/>
Insulation resistance:	<input type="text" value="1234567"/>	Earth fault loop impedance:	<input type="text" value="1234567"/>
Continuity:	<input type="text" value="1234567"/>	RCD:	<input type="text" value="1234567"/>

## 4 DECLARATION

I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations), amended to 2020, and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title:	<input type="text" value="JMEC Ltd"/>	Registration Number (if applicable):	<input type="text" value="04178900"/>				
Address:	<input type="text" value="Ingouville House&lt;br/&gt;Ingouville Lane&lt;br/&gt;St Helier"/>	Telephone Number:	<input type="text" value="01534 722888"/>				
	Postcode: <input type="text" value="JE2 4SG"/>						
Name:	<input type="text" value="Mr J Mcgranahan"/>	Position:	<input type="text" value="Qualified Supervisor"/>	Signature:	<input type="text" value="Handwritten signature"/>	Date:	<input type="text" value="14/04/2022"/>