


Certificate Number: 1234735

1 DESCRIPTION OF THE MINOR WORKS											
Client address: Brunel Management Brunel Chambers, Devonshire Place, St Helier, JE2 3RD	Installation address: 36 Belle Vue, La Route des Quennevais, St Brelade, JE3 8NH										
Description of the minor works: <table style="width: 100%; border-collapse: collapse;"> <tr><td style="width: 5%;">1):</td><td style="border: 1px solid black; padding: 2px;">New Kitchen. Cooker.</td></tr> <tr><td>2):</td><td style="border: 1px solid black; padding: 2px;">New Kitchen. Fridge.</td></tr> <tr><td>3):</td><td style="border: 1px solid black; padding: 2px;">New Kitchen. Washing Machine.</td></tr> <tr><td>4):</td><td style="border: 1px solid black; padding: 2px;">New Kitchen. Sockets.</td></tr> <tr><td>5):</td><td style="border: 1px solid black; padding: 2px;">N/A</td></tr> </table>		1):	New Kitchen. Cooker.	2):	New Kitchen. Fridge.	3):	New Kitchen. Washing Machine.	4):	New Kitchen. Sockets.	5):	N/A
1):	New Kitchen. Cooker.										
2):	New Kitchen. Fridge.										
3):	New Kitchen. Washing Machine.										
4):	New Kitchen. Sockets.										
5):	N/A										
Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5): Where applicable, a suitable risk assessment(s) must be attached to the Certificate. <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">None</div>											
Date minor works completed: 28/07/2022 Risk assessment attached: N/A											
Comments on (including any defects observed in) the existing installation (Regulation 644.1.2): <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">Satisfactory.</div>											

2 PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS	
System type and earthing arrangements:	TN-C-S <input checked="" type="checkbox"/> TN-S N/A TT N/A
Earth fault loop impedance at distribution board (Z _{db}) supplying the final circuit:	0.29 Ω
Presence of adequate main protective conductors:	Earthing Conductor <input checked="" type="checkbox"/>
Main protective bonding conductor(s) to:	Water <input checked="" type="checkbox"/> Gas <input checked="" type="checkbox"/> Oil N/A Structural Steel N/A Other: N/A

3 TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED	
See Page 2 for circuit details and test results.	
Details of Test Instruments used (state serial and/or asset numbers):	
Multi-functional:	101869907 Earth electrode resistance: N/A
Insulation resistance:	N/A Earth fault loop impedance: N/A
Continuity:	N/A RCD: N/A

4 DECLARATION	
I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works has been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations), amended to 2020, and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.	
Trading Title:	JMEC Ltd
Address:	Ingouville House Ingouville Lane St Helier
	Registration Number (if applicable): 04178900 Telephone Number: 01534 722888
	Postcode: JE2 4SG
Name:	Mr J Mcgranahan Position: Qualified Supervisor Signature:  Date: 16/08/2022