

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Requirements For Electrical Installations - BS 7671 IET Wiring Regulations

Certificate Number: 3050-LC80

1 DETAILS OF THE CLIENT

Client: Brunel Management

Address: Brunel Chambers, Devonshire Place, St.Helier, JE2 3RD

2 DETAILS AND EXTENT OF THE INSTALLATION

Installation Address: Flat 80 La Tour Indigo, Le Coie, Springfield Road, St.Helier, JE2 4JR

Extent of the installation covered by this certificate: 100% of the installation.

The installation is: New installation N/A Addition to an existing installation N/A Alteration to an existing installation

3 COMMENTS ON EXISTING INSTALLATION

Comments on existing installation (In the case of an addition or alteration see Regulation 644.1.2):

DB and protective devices upgrade is based on results of a recently carried out EICR. All observation and recommendations from the EICR have been rectified at this time.

No insulation resistance tests carried out between live conductors due to connected devices.

4 NEXT INSPECTION

I RECOMMEND that this installation is further inspected and tested after an interval of not more than:

5 Years or change of tenant/owner

5 TEST INSTRUMENTS

Details of Test Instruments used (state serial and/or asset numbers):

Multi-functional:	101109009	Earth electrode resistance:	N/A
Insulation resistance:	N/A	Earth fault loop impedance:	N/A
Continuity:	N/A	RCD:	N/A

6 DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I/We being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the design work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671:2018, amended to 2020 except for the departures, if any, detailed as follows.

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5):

None

Details of permitted exceptions (Regulations 411.3.3):

Risk assessment attached

N/A

None

The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.

For the DESIGN, the CONSTRUCTION, and the INSPECTION AND TESTING of the installation:

Name: Nick Barton Position: Manager Signature: *N Barton* Date: 07/07/2023

7 DETAILS OF THE ELECTRICAL CONTRACTOR

Trading Title: BARTON ELECTRICAL

Address: WOODLANDS FARM
LA RUE DE MAUPERTUIS
ST.HELIER, JERSEY

Postcode: JE2 3HG

Registration Number (if applicable): N/A

Telephone Number: 01534 611196