



- 4 FEB 2021

This report is not valid if the serial number has been defaced or altered

22483390

IPN18C

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

## PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR		DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION	
Registration No: 010706000	Branch No: 000	Contractor Reference Number (CRN): J154491	Occupier: N/A	
Trading Title: Small & Richards Electrical Contractors Ltd		Name: Brunel Management Limited	Address: 2 Warren Court, La Folie Estate, Parkinson Drive, La Route de St. Aubin, St. Lawrence,	
Address: Top Floor C Store, Halcyon House, West Hill, St. Helier, Jersey		Address: Brunel Chambers, Devonshire Place, St. Helier, JERSEY	JERSEY	
Postcode: JE2 3HB	Tel No: 01534 723503	Postcode: JE2 3RD	Tel No: 01534750200	Postcode: JE3 1JX Tel No: N/A

## PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required: Clients request and to meet the Jersey landlords legislation

Date(s) when inspection and testing was carried out: (30/07/2020 - 31/07/2020) Records available: (  ) Previous inspection report available: (  ) Previous report date: ( N/A )

## PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):  
The general condition of the installation is good. The installation is wired in pvc pvc with RCBOs at the fuse board. The installation is fit for purpose

Estimated age of electrical installation: ( 16 ) years Evidence of additions or alterations: (  ) Overall assessment of the installation is: **Satisfactory** ~~Unsatisfactory~~ \* (delete as appropriate)

## PART 4 : DECLARATION

### INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capitals): JAMES NORTON Signature: [Signature] Date: 31/07/2020

### REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE APPROVED CONTRACTOR

Name (capitals): JAMES NORTON Signature: [Signature] Date: 31/07/2020

\*An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that Further Investigation (CODE FI) without delay is required.

Original (to the person ordering the work)