



31 DEC 2019

This report is not valid if the serial number has been defaced or altered

20787776

IPN18C

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

## PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

### DETAILS OF THE CONTRACTOR

Registration No: 010706000 Branch No: 000  
 Trading Title: Small & Richards Electrical Contractors Ltd  
 Address: Top Floor C Store, Halcyon House, West Hill, St. Helier, Jersey  
 Postcode: JE2 3HB Tel No: 01534 723503

### DETAILS OF THE CLIENT

Contractor Reference Number (CRN): J156539  
 Name: Brunel Management Limited  
 Address: Brunel Management Limited, Devonshire Place, St. Helier, JERSEY  
 Postcode: JE2 3RD Tel No: 01534750200

### DETAILS OF THE INSTALLATION

Occupier: N/A  
 Address: 5 Maison de St. Nicolas, Le Vieux Beaumont, St. Peter, JERSEY  
 Postcode: JE3 7YP Tel No: N/A

## PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required: Scheduled report

Date(s) when inspection and testing was carried out: 06/12/2019 - 11/12/2019  
 Records available: ( X ) Previous inspection report available: ( X ) Previous report date: ( N/A )

## PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION


General condition of the installation (in terms of electrical safety):  
 The general condition of installation is satisfactory

Estimated age of electrical installation: ( 30 ) years Evidence of additions or alterations: ( X ) Overall assessment of the installation is: **Satisfactory/Unsatisfactory\*** (delete as appropriate)


## PART 4 : DECLARATION

### INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capitals): JAMES NORTON Signature:  Date: 11/12/2019

### REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE APPROVED CONTRACTOR

Name (capitals): JAMES NORTON Signature:  Date: 11/12/2019

\*An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that Further Investigation (CODE FI) without delay is required.