



3 1 AUG 2021

This report is not valid if the serial number has been defaced or altered

23846874

DPN18C

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Small installations up to 100 A single phase supply Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

| PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION | | |
|---|---|---|
| DETAILS OF THE CONTRACTOR Registration No: Trading Title: Smail & Richards Electrical Contractors Ltd Address: Top Floor C Store, Halcyon House, West Hill, St. Helier, Jersey | DETAILS OF THE CLIENT Contractor Reference Number (CRN): Name: Brunel Management Limited Address: Brunel Chambers, Devonshire Place, St. Helier, JERSEY | DETAILS OF THE INSTALLATION Occupier: Address: 8 Parkside, Peirson Road, St. Helier, JERSEY |
| Postcode: JE2 3HB Tel No: 01534723503 | Postcode: JE2 3RD Tel No: 750200 | Postcode: JE2 3PD Tel No: N/A |
| PART 2: PURPOSE OF THE REPORT | | |
| Purpose for which this report is required: Clients request and to meet the Jersey landlords legislation | | |
| | | |
| 0.100,0004 | | Y N/A |
| Date(s) when inspection and testing was carried out: 24/06/2021 Records available: (| | |
| PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION | | |
| General condition of the installation (in terms of electrical safety): The general condition of the installation is good. The installation is wired in pvc pvc with an Additional protection by RCD for sockets. The installation is fit for purpose. | | |
| | | |
| | f additions or alterations: () Overall assessment of the ins | stallation is: Satisfactory XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX |
| PART 4: DECLARATION | | |
| INSPECTION AND TESTING | | |
| I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing. | | |
| Name (capitals): | Signature: | Date: 13/08/2021 |
| REVIEWED BY QUALIFIED SUPERVISOR Name (capitals): JAMES NORTON | Signature: | Date: 13/08/2021 |

^{*}An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that Further Investigation (CODE FI) without delay is required.