



20 SEP 2021

This report is not valid if the serial number has been defaced or altered

23822004 DPN18C

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR

Registration No: 010706000 Branch No: 000
Trading Title: Small & Richards Electrical Contractors Ltd
Address: Top Floor C Store, Halcyon House, West Hill, St. Helier, Jersey
Postcode: JE2 3HB Tel No: 01534723503

DETAILS OF THE CLIENT

Contractor Reference Number (CRN): J160534
Name: Brunel Management Limited
Address: Brunel Chambers, Devonshire Place, St. Helier, JERSEY
Postcode: JE2 3RD Tel No: 750200

DETAILS OF THE INSTALLATION

Occupier: N/A
Address: 11 Parkside, Peirson Road, St. Helier, JERSEY
Postcode: JE2 3PD Tel No: N/A

PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required: Clients request and to meet the Jersey landlords legislation

Date(s) when inspection and testing was carried out: (14/06/2021 - 09/08/2021) Records available: (X) Previous inspection report available: (X) Previous report date: (N/A)

PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
The general condition of the installation is good. The installation is wired in pvc pvc with an Additional protection by RCD for sockets. The installation is fit for purpose

Estimated age of electrical installation: (25) years Evidence of additions or alterations: (X) Overall assessment of the installation is: Satisfactory/Unsatisfactory* (delete as appropriate)

PART 4 : DECLARATION

INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capitals): JAMES NORTON Signature: [Signature] Date: 17/06/2021

REVIEWED BY QUALIFIED SUPERVISOR

Name (capitals): JAMES NORTON Signature: [Signature] Date: 17/06/2021

*An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that Further Investigation (CODE FI) without delay is required.

Original (to the person ordering the work)