




MINOR ELECTRICAL INSTALLATION WORKS

For Electrical Installations - BS 7671 IET Wiring Regulations



Document Reference: 1234898

1 DESCRIPTION OF THE MINOR WORKS

Client address: Brunel Management
Brunel Management , Brunel Chambers,
Devonshire place , St Helier , JE2 3RD

Installation address: 5 St Saviours Court , St Saviours Road , St Helier , JE2 3TL

Description of the minor works:

- 1): Cooker
- 2): Kitchen Ring
- 3): Fridge and washing machine
- 4):
- 5):

Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5):
Where applicable, a suitable risk assessment(s) must be attached to the Certificate.

None

Date minor works completed: 27/08/2021 Risk assessment attached: N/A

Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):

2 PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS

System type and earthing arrangements: TN-C-S TN-S N/A TT N/A

Earth fault loop impedance at distribution board (Zdb) supplying the final circuit: 0.13 Ω

Presence of adequate main protective conductors: Earthing Conductor

Main protective bonding conductor(s) to: Water Gas N/A Oil N/A Structural Steel N/A Other: N/A

3 TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED

See Page 2 for circuit details and test results.

Details of Test Instruments used (state serial and/or asset numbers):


Multi-functional:	101722374	Earth electrode resistance:	N/A
Insulation resistance:	1234567	Earth fault loop impedance:	
Continuity:	1234567	RCD:	1234567

4 DECLARATION

I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations), amended to 2020, and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title: JMEC Ltd

Address: Ingouville House
Ingouville Lane
St Helier



Postcode: JE2 4SG

Registration Number (if applicable): 04178900

Telephone Number: 01534 722888

Name: Mr J Mcgranahan Position: Qualified Supervisor Signature:  Date: 27/08/2021