

MINOR ELECTRICAL INSTALLATION MULTIPLE WORKS

Requirements For Electrical Installations - BS 7671 IET Wiring Regulations

Certificate Reference: 1234650

1 DESCRIPTION OF THE MINOR WORKS

Client address:	Brunel Management Brunel Chambers, Devonshire Place, St Helier, JE2 3RD	Installation address:	8 St Saviours Court, St Saviours Road, St Helier, JE2 3 TL
-----------------	---	-----------------------	--

Description of the minor works:

- 1): Minor works. Kitchen. Cooker.
- 2): Minor works. Kitchen. Sockets. Ring Main.
- 3): Minor works. Kitchen. Sockets. Radial.
- 4): N/A
- 5): N/A

Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5):
Where applicable, a suitable risk assessment(s) must be attached to the Certificate.

None

Date minor works completed: 13/09/2021 Risk assessment attached: N/A

Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):

Satisfactory.

2 PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS

System type and earthing arrangements:	TN-C-S <input checked="" type="checkbox"/>	TN-S	<input type="checkbox"/> N/A	TT	<input type="checkbox"/> N/A				
Earth fault loop impedance at distribution board (Zdb) supplying the final circuit:	0.14 Ω								
Presence of adequate main protective conductors:	Earthing Conductor	<input checked="" type="checkbox"/>							
Main protective bonding conductor(s) to:	Water <input checked="" type="checkbox"/>	Gas	<input type="checkbox"/> N/A	Oil	<input type="checkbox"/> N/A	Structural Steel	<input type="checkbox"/> N/A	Other:	<input type="checkbox"/> N/A

3 TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED

See Page 2 for circuit details and test results.

Details of Test Instruments used (state serial and/or asset numbers):

Multi-functional:	101869907	Earth electrode resistance:	N/A
Insulation resistance:	N/A	Earth fault loop impedance:	N/A
Continuity:	N/A	RCD:	N/A

4 DECLARATION

I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations), amended to 2020, and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title:	JMEC Ltd	Registration Number (if applicable):	04178900				
Address:	Ingouville House Ingouville Lane St Helier	Telephone Number:	01534 722888				
	Postcode: JE2 4SG						
Name:	Mr J Mcgranahan	Position:	Qualified Supervisor	Signature:		Date:	14/09/2021